NOTES

1. SIZES OF INCOMING CABLES ARE STATED ON SCHEMATIC CABLE LAYOUT DIAGRAMS.
2. ALL MATERIALS AND EQUIPMENT SHALL COMPLY WITH BS60947-1 AS WELL AS FULLY COMPLYING WITH THE REQUIREMENTS OF THE LOW VOLTAGE DIRECTIVE AND BS EN 61000-6-3.
3. EARTHING OMITTED FOR CLARITY
4. ALL 24 VOLT CABLES SHALL BE LABELLED AS '24 VOLT SERVICE' TO DISTINGUISH BETWEEN THE DIFFERENT VOLTAGES WITHIN THE INSTALLATION

| | |
|---|---|
| Rev. No.: A | Standard Detail File Ref.: 05796.32 |
| Drawn: RPF | Title: |
| Ch'd: AB | TERMINATION DETAIL CONSUMER CUT-OUT / ISOLATOR WITH 24v SELV SUB-CIRCUIT |
| Auth'd: AB | |
| Date: 04/16 | |

Nottinghamshire County Council
Trent Bridge House, Fox Road,
West Bridgford, Nottingham, NG2 6BJ
**Tel:** 0300 500 80 80

| Drawing No.: | Scale: |
|---|---|
| **ESD 6/32** | N.T.S |