NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
2. CABLES SHALL COMPLY TO BS6724 AND BS EN 50525-3-11 AND BE MANUFACTURED AS XLPE/LSZH/SWA/LSZH.
3. CABLES SHALL HAVE STRANDED PLAIN ANNEALED COPPER(Cu) CONDUCTORS TO BS EN 60228:2005.
4. THE COLOUR IDENTIFICATIONS FOR EACH SINGLE PHASE THREE CORE CABLE CONDUCTOR SHALL BE AS FOLLOWS:

   PHASE: BROWN
   NEUTRAL: BLUE
   EARTH (CPC): GREEN/YELLOW

PLAN VIEW

CROSS SECTIONAL VIEW

Rev. No.:	Standard Detail File Ref.: 05796.68
Drawn: RPF	Title:
Ch'd: AB	STANDARD DETAIL FOR SINGLE PHASE MULTI-CORE XLPE/LSZH/SWA/LSZH PRIVATE NETWORK CABLE (URBAN ENVIRONMENT)
Auth'd: CA	
Date: 07/17	

Nottinghamshire County Council

Trent Bridge House, Fox Road,
West Bridgford, Nottingham, NG2 6BJ
Tel: 0300 500 80 80

Drawing No.:	Scale:
ESD 6/68	N.T.S