NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
2. CABLES SHALL COMPLY TO BS5467 AND IEC 60502 AND BE MANUFACTURED AS XLPE/PVC/SWA/PVC.
3. CABLES SHALL HAVE STRANDED PLAIN ANNEALED COPPER (Cu) CONDUCTORS TO BS EN 60228:2005.
4. THE COLOUR IDENTIFICATIONS FOR EACH THREE PHASE FIVE CORE CABLE CONDUCTOR SHALL BE AS FOLLOWS:

   PHASE L1: BROWN
   PHASE L2: BLACK
   PHASE L3: GREY
   NEUTRAL: BLUE
   EARTH (CPC): GREEN/YELLOW

PLAN VIEW

CROSS SECTIONAL VIEW

Rev. No.:	Standard Detail File Ref.: 05796.67
Drawn: RPF	Title:
Ch'd: AB	STANDARD DETAIL FOR THREE PHASE MULTI-CORE XLPE/PVC/SWA/PVC PRIVATE NETWORK CABLE
Auth'd: CA	
Date: 07/17	

Nottinghamshire County Council

Trent Bridge House, Fox Road,
West Bridgford, Nottingham, NG2 6BJ
Tel: 0300 500 80 80

Drawing No.:	Scale:
ESD 6/67	N.T.S