NOTES

1. CONSUMER CUT-OUT SHALL BE COMPLETE WITH 32A DOUBLE POLE ISOLATOR AND BS88 FUSE CARRIER(S) AND SHALL BE FUSED IN ACCORDANCE WITH THE MANUFACTURES RECOMMENDED FUSE VALUES.

2. INTERNAL WIRING BETWEEN THE CONSUMER CUT-OUT AND THE LUMINAIRE SHALL BE PVC/PVC FLEXIBLE CORD CABLE WITH PLAIN ANNEALED FLEXIBLE COPPER (Cu) CONDUCTORS TO BS EN 50525-2-11. CONDUCTORS SHALL BE NO LESS THAN 1.5mm² CROSS SECTIONAL AREA.

3. ALL SINGLE EARTH BONDING CABLES TO BE PVC 6mm² TRI-RATED GREEN/YELLOW.

4. COLOUR IDENTIFICATION SHALL BE:
   PHASE = BROWN
   NEUTRAL = BLUE
   EARTH BONDING/ C.P.C = GREEN / YELLOW

5. ARMOURED CABLE TERMINATIONS (IF APPLICABLE) TO STANDARD DETAIL DRAWING ESD6/30.

6. DRAWING TO BE READ IN CONJUNCTION WITH STANDARD DETAIL ESD 6/31.

7. ALL CABLES SHALL BE APPROPRIATELY CLIPPED OR CLEATED NEATLY.

8. ALL MATERIALS, EQUIPMENT AND WORKMANSHIP SHALL COMPLY WITH CURRENT BS7671: REQUIREMENTS FOR ELECTRICAL INSTALLATIONS (IEE WIRING REGULATIONS)

Rev. No.: C	Standard Detail File Ref.: 05796.37
Drawn: RPF	Title:
Ch'd: AB	TERMINATION DETAIL (T5) PRIVATE NETWORK SUPPLY WITH 230v SUB-CIRCUIT
Auth'd: CA	
Date: 09/17	

Nottinghamshire County Council

Trent Bridge House, Fox Road,
West Bridgford, Nottingham, NG2 6BJ
Tel: 0300 500 80 80

Drawing No.: **ESD 6/37**	Scale: N.T.S