


NOTES

1. CONSUMER ISOLATOR SHALL BE COMPLETE WITH 32A DOUBLE POLE ISOLATOR AND BS88 FUSE CARRIER(S) AND SHALL BE FUSED IN ACCORDANCE WITH THE MANUFACTURES RECOMMENDED FUSE VALUES.
2. THE FINAL CONNECTION BETWEEN THE CONSUMER ISOLATOR AND DNO EQUIPMENT SHALL BE PVC OR XLPE INSULATED AND SHEATHED SINGLE CORE CABLE, APPROPRIATELY SIZED FOR CURRENT CARRYING CAPACITY AND OF A MINIMUM C.S.A OF 2.5mm².
3. INTERNAL WIRING BETWEEN THE CONSUMER ISOLATOR AND THE LUMINAIRE SHALL BE PVC/PVC FLEXIBLE CORD CABLE WITH PLAIN ANNEALED FLEXIBLE COPPER (Cu) CONDUCTORS TO BS EN 50525-2-11. CONDUCTORS SHALL BE NO LESS THAN 1.5mm² CROSS SECTIONAL AREA.
4. ALL SINGLE EARTH BONDING CABLES SHALL BE TRI-RATED GREEN/YELLOW. *(THE CROSS SECTIONAL AREAS OF BONDING CABLES SHALL BE AS DENOTES IN DIAGRAM)*
5. COLOUR IDENTIFICATION SHALL BE:
 PHASE = BROWN
 NEUTRAL = BLUE
 EARTH BONDING/ C.P.C = GREEN / YELLOW
6. ALL CABLES SHALL BE APPROPRIATELY CLIPPED OR CLEATED NEATLY.
7. ALL MATERIALS, EQUIPMENT AND WORKMANSHIP SHALL COMPLY WITH CURRENT BS7671: REQUIREMENTS FOR ELECTRICAL INSTALLATIONS (IEE WIRING REGULATIONS)



Rev. No.:
D

Standard Detail File Ref.: 05796.33

Drawn:
RPF

Title:

Ch'd:
AB

DISTRIBUTION NETWORK OPERATOR (DNO) SERVICE TERMINATION (T1)

Auth'd:
RD

Date: 07/22



**Nottinghamshire
County Council**

Trent Bridge House, Fox Road,
West Bridgford, Nottingham, NG2 6BJ
Tel: 0300 500 80 80

Drawing No.:
ESD 6/33

Scale:
N.T.S