

GROUP D2 - DRAINS AND SEWERS UNDER ROADS AND VERGES

Asbestos Cement Pipes to BS EN 588-1:1997

PIPE DIA (mm)	COVER (METRES)	TYPE OF BEDDING	CLASS OF PIPE
150	0.6 - 6.0	B	H
225	0.9 - 6.0	B	H
300	0.9 - 4.0	B	M
	4.0 - 6.0	A OR B	M H
375	0.9 - 3.0	B	M
	3.0 - 6.0	A OR B	M H
450	0.9 - 3.1	A	L
	3.1 - 3.6	OR B A	M L
	3.6 - 6.0	A OR B	M H
525	0.9 - 1.2	A	L
	1.2 - 2.3	A	L
	2.3 - 3.8	OR B A	M L
	3.8 - 6.0	A OR B	M H
600	0.9 - 1.0	A	M
	1.0 - 2.6	A	L
	2.6 - 6.0	OR B A	M M
		OR B	A H

Asbestos Cement Pipes to BS EN 588-1:1997

PIPE DIA (mm)	COVER (METRES)	TYPE OF BEDDING	CLASS OF PIPE
675	0.9 - 3.0	B	L
	3.0 - 3.4	OR B A	M L
	3.4 - 6.0	A OR B	M H
750	0.9 - 1.0	A	M
	1.0 - 3.0	A OR B	L M
	3.0 - 6.0	A OR B	M H
825	0.9 - 1.0	A	M
	1.0 - 3.2	A OR B	L M
	3.2 - 6.0	A OR B	M H
900	0.9 - 1.2	B	M
	1.2 - 2.0	A	L
	2.0 - 3.0	OR B B	M M
		A	M
	3.0 - 5.2	OR B A	H M

Ductile Iron to BS EN 969:2009, BS EN 545:2002 & BS EN 598:2007+A1:2009

PIPE DIA (mm)	COVER (METRES)	TYPE OF BEDDING	CLASS OF PIPE
150	0.6 - 6.0	Q	K9
225	0.6 - 6.0	Q	K9
300	0.6 - 6.0	Q	K9
450	1.0 - 6.0	Q	K9
600	1.3 - 6.0	Q	K9

NOTES:

For Notes see Drg No SD/5/5.

Rev.	Description	Drawn	Ch'kd	Auth	Date



in partnership with



**Nottinghamshire
County Council**

www.viam.co.uk Tel 0115 804 2100

Bilsthorpe Depot, Bilsthorpe Business Park, Bilsthorpe,
Nottinghamshire, NG22 8ST

Project		Highway Construction Details			Project	Drawn	Date
Status	Project No.	DRAINAGE			Ch'kd	JLS	10/06/2020
Drawing Title	Group D2 - Tables of Strengths and Depths				Auth	JJP	24/06/20
Drawing No.	SD/5/7				Rev.	0	Traced JLS Scale N.T.S @A4