



NOTES:

1. All dimensions are in millimetres unless otherwise stated.
2. Depth of gland plate not less than 55mm.
3. PVC shroud to be a tight fit on cable sheath and gland.
4. Label to be fitted below lock nut.
5. Colour identification shall be achieved via sleeving of the exposed core as follows:-
 YELLOW = GREEN/YELLOW
 BLUE = BLACK
 BROWN = RED



in partnership with



www.viaem.co.uk Tel 0115 804 2100

Bilsthorpe Depot, Bilsthorpe Business Park, Bilsthorpe,
Nottinghamshire, NG22 8ST

Project		Highway Construction Details			Project	Drawn	Ch'kd	Auth	Date
Status		Street Lighting				JLS			13/08/2020
Drawing Title		Armoured Cable Termination				JD			04/02/2021
Drawing No.		SD/14/07				JP		JLS	
						0			N.T.S @A4