


FOR CABLE SIZES UP TO 10.0mm<sup>2</sup> (TYPE T3) - OVER 10.0mm<sup>2</sup> (TYPE T4)



NOTES:

1. All dimensions are in millimetres unless otherwise stated.
2. All terminations shall comply fully with the Model Contract Document for Highway Works (MCDHW) Specification.
3. All BS 88 fuses shall be rated in accordance with the equipment manufacturer's requirements.
4. For 'warning' label details see Drg No SD/14/10.
5. For source/destination label details see Drg No SD/14/9.
6. All equipment shall be fixed to the backboard using stainless steel screws.

| Rev. | Description | Drawn | Ch'kd | Auth | Date |
|------|-------------|-------|-------|------|------|
|      |             |       |       |      |      |
|      |             |       |       |      |      |



in partnership with  
**Nottinghamshire County Council**  
 www.viaem.co.uk Tel 0115 804 2100  
 Bilsthorpe Depot, Bilsthorpe Business Park, Bilsthorpe,  
 Nottinghamshire, NG22 8ST

|               |             |                                  |  |  |         |       |                    |
|---------------|-------------|----------------------------------|--|--|---------|-------|--------------------|
| Project       |             | Highway Construction Details     |  |  | Project | Drawn | Date               |
| Status        | Project No. | Street Lighting                  |  |  |         | JLS   | 14/08/2020         |
| Drawing Title |             | Cable Termination Type T3 And T4 |  |  | Ch'kd   | JD    | 05/02/2021         |
| Drawing No.   |             | SD/14/14                         |  |  | Auth    | JP    | Traced<br>JLS      |
|               |             |                                  |  |  | Rev.    | 0     | Scale<br>N.T.S @A4 |

Apr 16, 2021 - 2:09pm: I:\Highways\Design and Construction\Roads and Highways\Projects\B-1920000\20871 New Hwy Design\Guide for New Dev\Design\CAD\New standard details\NCC SD\14\07 Series\SD\_14\_14.dwg